



Gentlemen;
The Preamble states that each
Hydraulic system is to be tested for PCB, and that
Heat Transfer Systems are to be treated similar to
Hydraulic systems. There are no comments indicating
you can consolidate samples and make one test.

INTERNAL CORRESPONDENCE

SILICONES & URETHANE INTERMEDIATES

Bldg. 3005-256
South Charleston, WV 25303

TO: F. E. Dailey
R. D. Nelson
J. L. Worstell

DATE: August 9, 1984

FROM: R. L. Foster

ORIG. DEPT: Environmental Affairs

CC: G. W. Jackson
D. Liebeskind
R. A. Matthews
S. Rossi
W. V. Summers, Jr.

SUBJECT: Hydraulic and Heat Transfer
Systems Contamination, PCB's

Gentlemen:

It has been over five years since the PCB Regulations were first finalized and published. While reading the latest revisions of the PCB regulations I was reminded that you have only maintained your PCB records for five years. If you purged your files you may have inadvertently destroyed the results of the testing of the subject systems for PCB contamination as required by the regulations. The regulations state that if the concentration of PCB is below 50 ppm you do not have to perform annual test of the systems. Therefore, I would recommend that you immediately review your files for this information and, if you can't find it, I would suggest that you initiate an immediate program to retest the systems.

Please contact me if you have questions about this issue.

Sincerely,

Bob / X

R. L. Foster

MPM000771

EPA004350